

Kathy Catazaro-Perry, Mayor



CITY OF MASSILLON, OHIO

151 LINCOLN WAY EAST
MUNICIPAL GOVERNMENT ANNEX
CITY ADMINISTRATION BUILDING
MASSILLON, OHIO 44646
PHONE 330-830-1722 FAX 330-830-1786

PERMIT DATE:

6/6/2012

PERMIT NO.

4195

PERMIT TO TAP SANITARY SEWER

This permit is issued subject to the latest Codified Ordinances of the City of Massillon, OH. The City Engineer to be notified 24 hours in advance of start of work (330) 830-1722. All permits issued under this ordinance are void after 120 days from date of issuance.

RECEIVED OF:

PERMIT TYPE New

CONTRACTOR INFORMATION

SITE INFORMATION

CONTRACTOR: MALAVITE EXCAVATING

OWNER'S NAME: CROCKETT HOMES

CONTACT: GUS

FULL STREET ADDRESS: 1390 KELLY ST SW

ADDRESS: _____

CITY LOT NUMBER 16227

CITY: _____

PURPOSE OF CUT: SANITARY

STATE: _____

ZONING CLASS: _____

ZIP: _____

STREET SIDE: South

PHONE: _____

FAX: _____

SURETY: _____

PHONE OTHER: _____

SANITARY SEWER CONNECTION:

NOTE: This permit covers work outside of the building ONLY. Any work inside walls of the building is subject to the Massillon Board of Health Regulations.

USE: Residential

SKETCH: DRAWING #: _____

DATE INSPECTED 6/13/2012

located on the EAST side of

KELLY ST SW between

LINDA LANE and

CULDESAC

Direction from downstream Manhole: NORTH

SEE NEXT PAGE

Distance from downstream Manhole: 66'

Connection Length: 47.00 (FEET)

Connection Depth: 6 (FEET)

Size of Sewer Pipe: 6 (INCHES)

Pipe Material: PVC

INSPECTORS NAME: JASON HAINES

INSPECTION REQUEST: _____

COMMENTS: 10" OF FALL

SANITARY SEWER PERMIT FEE: \$100.00

CAPACITY FEE: \$500.00

TOTAL COST: \$600.00

TWO WORKING DAYS BEFORE YOU DIG
Ohio Utilities Protection Service
Call 1-800-362-2764 Toll Free....
Non-Members must be called directly.

AUTHORIZED BY: DIRECTOR OF PUBLIC SAFETY AND SERVICE

ISSUED BY: Jeffery King

North

Kelly St
SW

Ex 8" main

Ex Lateral

66' from manhole

Existing Trunk Sewer

Creek

Manhole

Reducer to ABS pipe

Clear out

6x6
12x12

45'

23'

11'

House #1390

Goes in 10' from back corner 5' deep