



Kathy Catazaro-Perry, Mayor

CITY OF MASSILLON, OHIO

151 LINCOLN WAY EAST
MUNICIPAL GOVERNMENT ANNEX
CITY ADMINISTRATION BUILDING
MASSILLON, OHIO 44646
PHONE 330-830-1722 FAX 330-830-1786

PERMIT DATE:

12/6/2013

PERMIT NO.

4296

PERMIT TO TAP SANITARY SEWER

This permit is issued subject to the latest Codified Ordinances of the City of Massillon, OH. The City Engineer to be notified 24 hours in advance of start of work (330) 830-1722. All permits issued under this ordinance are void after 120 days from date of issuance.

RECEIVED OF:

CONTRACTOR INFORMATION

CONTRACTOR: HOLDERBAUM
CONTACT: CITY OF MASSILLON
ADDRESS:
CITY:
STATE:
ZIP:
PHONE: (330) 830-1722
FAX:
SURETY:

PERMIT TYPE Repair

SITE INFORMATION

OWNER'S NAME: BODIFORD
FULL STREET ADDRESS: 1118 WALNUT RD SE
CITY LOT NUMBER 16612
PURPOSE OF CUT: REPAIR
ZONING CLASS:
STREET SIDE:
PHONE OTHER:

SANITARY SEWER CONNECTION:

USE: Residential

DATE INSPECTED 12/6/2013

located on the NORTH side of

WALNUT RD SE between
JOHNSON STSE and
11TH ST SE

Direction from downstream Manhole:

Distance from downstream Manhole:

Connection Length: 10.00 (FEET)

Connection Depth: (FEET)

Size of Sewer Pipe: 4 (INCHES)

Pipe Material: PVC

INSPECTORS NAME: FRED WERNER

COMMENTS: EMERGENCY REPAIR Lateral
was broken when gas co.
Replaced gas lines

NOTE: This permit covers work outside of the building ONLY. Any work inside walls of the building is subject to the Massillon Board of Health Regulations

SKETCH: DRAWING #:

INSPECTION REQUEST: 12/6/13

SANITARY SEWER PERMIT FEE: \$0.00

CAPACITY FEE: \$0.00

TOTAL COST: \$0.00

TWO WORKING DAYS BEFORE YOU DIG
Ohio Utilities Protection Service
Call 1-800-362-2764 Toll Free....
Non-Members must be called directly.

AUTHORIZED BY: DIRECTOR OF PUBLIC SAFETY AND SERVICE

ISSUED BY: Linda Mikutel

Clean-Out

(SA)

ex. 4" lateral

4" to 4" plastic fernco

4" plastic to 4" clay fernco

4"

6"

4" plastic to 4" clay fernco

ex 6" san

(SA)

(SA)