

Kathy Catazaro-Perry, Mayor



CITY OF MASSILLON, OHIO

151 LINCOLN WAY EAST
MUNICIPAL GOVERNMENT ANNEX
CITY ADMINISTRATION BUILDING
MASSILLON, OHIO 44646
PHONE 330-830-1722 FAX 330-830-1786

PERMIT DATE:

5/5/2014

PERMIT NO.

4338

PERMIT TO TAP SANITARY SEWER

This permit is issued subject to the latest Codified Ordinances of the City of Massillon, OH. The City Engineer to be notified 24 hours in advance of start of work (330) 830-1722. All permits issued under this ordinance are void after 120 days from date of issuance.

RECEIVED OF:

PERMIT TYPE New

CONTRACTOR INFORMATION

SITE INFORMATION

CONTRACTOR: WENGER EXCAVATING

OWNER'S NAME: TOBIN CONSTRUCTION

CONTACT: DAVE BLOSSER

FULL STREET ADDRESS: 2517-2547 RICHVILLE DR SE

ADDRESS: _____

CITY: _____

CITY LOT NUMBER OL 901

STATE: _____

PURPOSE OF CUT: TAP SANITARY

ZIP: _____

ZONING CLASS: RM1

PHONE: (330) 495-6108

STREET SIDE: South

FAX: _____

SURETY: _____

PHONE OTHER: (330) 497-9744

SANITARY SEWER CONNECTION:

NOTE: This permit covers work outside of the building ONLY. Any work inside walls of the building is subject to the Massillon Board of Health Regulations

USE: Residential

SKETCH: DRAWING #: _____

DATE INSPECTED 5/29/2014

located on the SOUTH side of
RICHVILLE DR SE between
JACKSON AVE SE and
OHIO STATE DR SE

Direction from downstream Manhole: NORTH

Distance from downstream Manhole: TIES INTO

Connection Length: 98.00 (FEET)

Connection Depth: 4 (FEET)

Size of Sewer Pipe: 6 (INCHES)

Pipe Material: PVC

INSPECTORS NAME: JASON HAINES

INSPECTION REQUEST: 5/8/14

COMMENTS: (2) 3 UNIT BUILDINGS AKA
BUCKEYE VILLAGE
APARTMENT

SANITARY SEWER PERMIT FEE: \$250.00

CAPACITY FEE: \$6,000.00

TOTAL COST: \$6,250.00

TWO WORKING DAYS BEFORE YOU DIG
Ohio Utilities Protection Service
Call 1-800-362-2764 Toll Free....
Non-Members must be called directly.

AUTHORIZED BY: DIRECTOR OF PUBLIC SAFETY AND SERVICE

ISSUED BY: Jason Haines

NORTH

Richville Drive SE

Lateral 4" 4 foot deep
except 4" 6-7 foot
under landscape mound

Building #1
Address 2517

Building #2
Address 2547

Landscape mound
with trees/lawn

Existing 12" storm line (chore)
Unknown beginning and end...

clean out
wyse up

Broke storm line and tied 5"
lays on top of sanitary line
No bedding on storm line
(Private)

8" main
flows west
beside Candas

Sanitary
Manhole
4' deep

Tied on to existing 6" lateral
@ 50' from Manhole.
No bedding on existing pipe

Unknown
storm sewer