



Kathy Catazaro-Perry, Mayor

# CITY OF MASSILLON, OHIO

151 LINCOLN WAY EAST  
MUNICIPAL GOVERNMENT ANNEX  
CITY ADMINISTRATION BUILDING  
MASSILLON, OHIO 44646  
PHONE 330-830-1722 FAX 330-830-1786

PERMIT DATE:

10/20/2014

PERMIT NO.

422

## PERMIT TO TAP SANITARY SEWER

This permit is issued subject to the latest Codified Ordinances of the City of Massillon, OH. The City Engineer to be notified 24 hours in advance of start of work (330) 830-1722. All permits issued under this ordinance are void after 120 days from date of issuance.

### RECEIVED OF:

### CONTRACTOR INFORMATION

CONTRACTOR: \_\_\_\_\_  
CONTACT: MATT  
ADDRESS: \_\_\_\_\_  
CITY: \_\_\_\_\_  
STATE: \_\_\_\_\_  
ZIP: \_\_\_\_\_  
PHONE: (330) 936-3548  
FAX: \_\_\_\_\_  
SURETY: \_\_\_\_\_

PERMIT TYPE New

### SITE INFORMATION

OWNER'S NAME: FAMILY DOLLAR  
FULL STREET ADDRESS: 2625 LINCOLN WAY E  
CITY LOT NUMBER: 17448  
PURPOSE OF CUT: SANITARY  
ZONING CLASS: \_\_\_\_\_  
STREET SIDE: \_\_\_\_\_

PHONE OTHER: \_\_\_\_\_

NOTE: This permit covers work outside of the building ONLY. Any work inside walls of the building is subject to the Massillon Board of Health Regulations.

### SANITARY SEWER CONNECTION:

USE: Commercial

DATE INSPECTED 10/28/2014

located on the SOUTH side of  
LINCOLN WAY E between  
26TH ST SE and  
27TH ST SE

Direction from downstream Manhole: EAST

Distance from downstream Manhole: 181'

Connection Length: 98.00 (FEET)

Connection Depth: 8 (FEET)

Size of Sewer Pipe: 6 (INCHES)

Pipe Material: PVC

INSPECTORS NAME: JASON HAINES

COMMENTS:

SKETCH: DRAWING #: 4381

INSPECTION REQUEST:

SANITARY SEWER PERMIT FEE: \$250.00

CAPACITY FEE: \$1,750.00

TOTAL COST: \$2,000.00

TWO WORKING DAYS BEFORE YOU DIG  
Ohio Utilities Protection Service  
Call 1-800-362-2764 Toll Free....  
Non-Members must be called directly.

AUTHORIZED BY: DIRECTOR OF PUBLIC SAFETY AND SERVICE

ISSUED BY: Linda Mikutel

26th Street SE



curb line 2

manhole

181' from manhole to existing wye

Existing sewer main  
under sidewalk area  
Flows west

Lincoln Way East

curb line

Fence  
clay to PVC

used Existing wye and  
5' of clay pipe.  
Removed concrete cap  
from house demolition

clean out up  
← wye 45°

68'

16'

6" to 4" reducer

Comes out 8' from  
NW corner of building  
4" pipes under footer

Family Dollar Store  
Address # 2625 Lincoln Way

