

Kathy Catazaro-Perry, Mayor



CITY OF MASSILLON, OHIO

151 LINCOLN WAY EAST
MUNICIPAL GOVERNMENT ANNEX
CITY ADMINISTRATION BUILDING
MASSILLON, OHIO 44646
PHONE 330-830-1722 FAX 330-830-1786

PERMIT DATE:

1/4/2016

PERMIT NO.

201600001

PERMIT TO TAP SANITARY SEWER

This permit is issued subject to the latest Codified Ordinances of the City of Massillon, OH. The City Engineer to be notified 24 hours in advance of start of work (330) 830-1722. All permits issued under this ordinance are void after 120 days from date of issuance.

RECEIVED OF:

CONTRACTOR INFORMATION

CONTRACTOR: UNDERGROUND SERVICES
CONTACT: BOB FISHER
ADDRESS: P. O. BOX 190
CITY: UNIONTOWN
STATE: OH
ZIP: 44685-
PHONE: (330) 323-0166
FAX: (330) 494-2624
SURETY: CINCINNATI

PERMIT TYPE Repair

SITE INFORMATION

OWNER'S NAME:
FULL STREET ADDRESS: 116 MAPLE AVE SE
CITY LOT NUMBER 2356
PURPOSE OF CUT: REPAIR
ZONING CLASS:
STREET SIDE: North

PHONE OTHER:

SANITARY SEWER CONNECTION:

USE: Residential

DATE INSPECTED 1/25/2016

located on the NORTH side of
MAPLE AVE SE between
1ST ST SE and
2ND ST SE

Direction from downstream Manhole: EAST

Distance from downstream Manhole: 156'

Connection Length: 62.50 (FEET)

Connection Depth: 7 (FEET)

Size of Sewer Pipe: 6 (INCHES)

Pipe Material: PVC

INSPECTORS NAME: JASON HAINES

COMMENTS: Relaid lateral from wye to house foundation

NOTE: This permit covers work outside of the building ONLY. Any work inside walls of the building is subject to the Massillon Board of Health Regulations.

SKETCH: DRAWING #:

INSPECTION REQUEST:

SANITARY SEWER PERMIT FEE: \$75.00

CAPACITY FEE: \$0.00

TOTAL COST: \$75.00

TWO WORKING DAYS BEFORE YOU DIG
Ohio Utilities Protection Service
Call 1-800-362-2764 Toll Free....
Non-Members must be called directly.

AUTHORIZED BY: DIRECTOR OF PUBLIC SAFETY AND SERVICE

ISSUED BY: Linda Mikutel



1st Street SE

curb line

Brick sidewalk



House #
114

Existing pipe
goes under floor

Steel back
Fernco

61' new pipe

under gas line

under waterline

156' from manhole

450
18" up

Existing wye -

Top was broken off existing wye
Repair made with new pvc (vertical)
and concrete encasement

Alley - Avon Place

Maple Ave SE

6" sewer main
Flows west