



Kathy Catazaro-Perry, Mayor

CITY OF MASSILLON, OHIO

151 LINCOLN WAY EAST
MUNICIPAL GOVERNMENT ANNEX
CITY ADMINISTRATION BUILDING
MASSILLON, OHIO 44646
PHONE 330-830-1722 FAX 330-830-1786

PERMIT DATE:

6/16/2016

PERMIT NO.

201600036

PERMIT TO TAP SANITARY SEWER

This permit is issued subject to the latest Codified Ordinances of the City of Massillon, OH. The City Engineer to be notified 24 hours in advance of start of work (330) 830-1722. All permits issued under this ordinance are void after 120 days from date of issuance.

RECEIVED OF:

PERMIT TYPE Cut Off

CONTRACTOR INFORMATION

CONTRACTOR: MARSHALL LAND CO

CONTACT: JAMES MARSHALL

ADDRESS: 138 12TH ST NW

CITY: CANTON

STATE: OHIO

ZIP: 44703-

PHONE: (330) 284-2378

FAX: (330) 313-1008

SURETY: STATE AUTO

SITE INFORMATION

OWNER'S NAME:

FULL STREET ADDRESS:

1329 KRACKER ST NW

CITY LOT NUMBER 2534

PURPOSE OF CUT: DEMOLITION

ZONING CLASS:

STREET SIDE:

PHONE OTHER:

SANITARY SEWER CONNECTION:

USE: Residential

DATE INSPECTED 6/17/2016

located on the WEST side of

KRACKER ST NW between

LAKE AVE NE and

NISH AVE

Direction from downstream Manhole: SOSOUTH

Distance from downstream Manhole: 23'

Connection Length: (FEET)

Connection Depth: 7 (FEET)

Size of Sewer Pipe: 6 (INCHES)

Pipe Material: CLAY

INSPECTORS NAME: JASON/FRED

COMMENTS: Measured from upstream MH lateral is flowing backwards, needs re-laid

NOTE: This permit covers work outside of the building ONLY. Any work inside walls of the building is subject to the Massillon Board of Health Regulations.

SKETCH: DRAWING #:

INSPECTION REQUEST: 6/17/16

SANITARY SEWER PERMIT FEE: \$15.00


CAPACITY FEE: \$0.00

TOTAL COST: \$15.00

TWO WORKING DAYS BEFORE YOU DIG
Ohio Utilities Protection Service
Call 1-800-362-2764 Toll Free....
Non-Members must be called directly.

AUTHORIZED BY: DIRECTOR OF PUBLIC SAFETY AND SERVICE

ISSUED BY: Linda Mikutel



Capped 15'
from main sewer
About 7.5' deep

Lateral is flat and
flowing backwards.
Will need to be re-laid

Lake Ave

